

PCB MARKING AND RECORDKEEPING REUQUIREMENTS

REGULATED ITEMS	MARKING REQUIREMENTS	IN SERVICE RECORDS	DISPOSAL AND STORAGE-FOR DISPOSAL RECORDS
PCB Containers	M _L	- Total Kg weight of all containers * - Description of contents *	- Date container - Serial or I.D.# * - Kg weight of each * - Description of contents* - Dates for: removal, transport, disposal* - Total # & Kg weight *
PCB Article Containers	M _L	- Total Kg weight of all containers * - Description of contents *	- Date container - Serial or I.D.# * - Kg weight of each * - Description of contents* - Dates for: removal, transport, disposal * - Total # & Kg weight *
PCB Transformers Voltage Regulators	M _L M _L or approved mark on access to unit (e.g., fence or vault doors)	- Total # of units - Total Kg weight - Inspection & maintenance - Registration with EPA - Record of sale	- Date article - Serial or I.D.# * - Kg of fluid in each * - Dates for: removal, transport, disposal * - Total # & Kg weight *
PCB Large High or Low Voltage Capacitors	M _L on unit or on protected location	- Total # (- protected location records if applicable - Record of sale	- Date article - Serial or I.D. # * - Kg of fluid in each * - Dates for: removal, transport, disposal * - Total # & Kg weight *
PCB Small Capacitor	**		
PCB-Contaminated Electrical Equipment	Not Required	- Record of sale	- Not required (once drained)
PCB Equipment that contains a PCB Large Capacitors or PCB Transformers	M _L	Records required for PCB Large Capacitors or PCB Transformers	Records required for PCB Large Capacitors or PCB Transformers
Natural Gas Pipeline Compressors, Appurtenances & Air Compressor systems (<2 ppm)	M _L on above ground sources of PCB liquids >50 ppm		
Bulk PCB waste	M _L on container		- Kg weight/quantity dates of each batch in or out. Also disposition of each batch out. - Total Kg weight

* Annual reporting requirement

** Manufacturers are required to mark non-PCB Large Low Voltage capacitors, small capacitors, and fluorescent light ballasts with a "No PCBs" label until 1 July 1998.

Storage areas	M _L	Record of cleanups and inspections for leaks	- Annual records as required under §761.180 - Records of attempts to comply with 1-year limit (if necessary)
Transport vehicles	M _L if contains a PCB transformer of 45kg liquid PCBs		
PCB motors, hydraulic and heat-transfer systems	M _L (Note: use of these items no longer authorized)		

* Annual reporting requirement

** Manufacturers are required to mark non-PCB Large Low Voltage capacitors, small capacitors, and fluorescent light ballasts with a "No PCBs" label until 1 July 1998.